



Misty @ DNR

Department of Public Utilities

Garrett County Sanitary District, Inc.



E-MAILED Dale Baker

2008 Maryland Highway, Suite #2, Mtn. Lake Park, Maryland 21550

Telephone 301-334-6983 • Fax 301-334-6984 • E-mail: publicutilities@garrettcountry.org

TELEPHONE REPORT OF SEWAGE OVERFLOW

EMERGENCY PHONE # 866-633-4686

In What County did the Overflow Occur	Garrett	
Is this a combined sewer overflow (CSO)	YES <input type="radio"/> NO <input checked="" type="radio"/> (CIRCLE ONE)	
When did the Overflow Occur	DATE: August 15, 2015	TIME 11:33 AM/PM <input checked="" type="radio"/>
Is the Overflow Ongoing or has it been repaired	ONGOING <input type="radio"/> REPAIRED <input checked="" type="radio"/> (CIRCLE ONE)	DURATION OF INCIDENT: Stopped 11:45 AM 8/15/15
Location of the Overflow: Street, Manhole #, Pump Station name, etc.	Pump station # 8-3 Marsh Hill rd. Meltenry Md.	
Cause of the Overflow - Get as much information as possible.	Bad wire in Control Cord on pump kept Blowing Control fuse, knocking out controls.	
What has been done to correct the Cause of the Overflow	Control Cord on pump has been repaired, pump will be replaced @ earliest convenience	
Did any of the Overflow Waste Water enter Waters of the State (includes storm drains)	YES <input type="radio"/> NO <input checked="" type="radio"/> (CIRCLE ONE)	NAME OF THE BODY OF WATER (IF YES)
Has/will the public be notified? If yes, how?	No	
Has/will the affected water body be posted as being contaminated?	No	
Estimated Quantity of the Overflow in GALLONS	200 gallons	
What type of Clean-up or other mitigation is being performed or scheduled to be performed	No visible debris on ground lime stabilized Affected area	
Name of the Person Reporting the Overflow	NAME: John M.C. Miller	PHONE: (301) 501-1109
	TITLE: Superintendent	
Name and type of Facility	FACILITY NAME: DeepCreek lake	TYPE OF FACILITY: Collections
Written Follow-up Notice	REMINDE THE CALLER THAT A WRITTEN FOLLOW-UP IS REQUIRED WITHIN 5 CALENDER DAYS (UNLESS THIS IS A CITIZEN COMPLAINT)	
Name of Staff Receiving Report	Jon Inskeep	
Date and Time of Report	DATE: 8/15/15	TIME: 1:28 AM/PM <input checked="" type="radio"/>
Name of Staff Report was referred to for follow-up	Paul Ferreri called back 8/15/15 @ 1:34 pm	
Copy Provided to	Dave Lyons; Bill Lee; Inspection Division Chief; inspector	

Reported to Steve Sherard Garrett County Health Dept. 8/15/15 @ 1:19 pm