

# Department of Public Utilities

Garrett County Sanitary District, Inc.

2008 Maryland Highway, Suite #2, Mtn. Lake Park, Maryland 21550

Telephone 301-334-6983 • Fax 301-334-6984 • E-mail: publicutilities@garrettcountry.org

## TELEPHONE REPORT OF SEWAGE OVERFLOW

EMERGENCY PHONE # 866-633-4686

In What County did the Overflow Occur	<b>Garrett</b>	
Is this a combined sewer overflow (CSO)	YES      NO (CIRCLE ONE)	
When did the Overflow Occur	DATE: 5-31-15	TIME: 2:15 PM AM/PM
Is the Overflow Ongoing or has it been repaired	ONGOING (CIRCLE ONE) <b>REPAIRED</b>	DURATION OF INCIDENT:
Location of the Overflow: Street, Manhole #, Pump Station name, etc.	264 Grandview DR. Deep Creek Lake Md.      Note: Mtn Side	
Cause of the Overflow - Get as much information as possible.	Believe line was hit when water line was installed and check valve went bad.	
What has been done to correct the Cause of the Overflow	Capped end of pipe	
Did any of the Overflow Waste Water enter Waters of the State (includes storm drains)	YES (CIRCLE ONE) <b>NO</b>	NAME OF THE BODY OF WATER (IF YES)
Has/will the public be notified? If yes, how?		
Has/will the affected water body be posted as being contaminated?	NO	
Estimated Quantity of the Overflow in GALLONS	300 gal.	
What type of Clean-up or other mitigation is being performed or scheduled to be performed	Lined area	
Name of the Person Reporting the Overflow	NAME: James Kemner TITLE: Oper. Supervisor	PHONE: 301-501-1842
Name and type of Facility	FACILITY NAME: DCL	TYPE OF FACILITY:
Written Follow-up Notice	REMINDE THE CALLER THAT A WRITTEN FOLLOW-UP IS REQUIRED WITHIN 5 CALENDER DAYS (UNLESS THIS IS A CITIZEN COMPLAINT)	
Name of Staff Receiving Report	MDE - Kevin Weis	
Date and Time of Report	DATE: 6-1-15	TIME: 10:15 AM/PM
Name of Staff Report was referred to for follow-up	Kevin Weis	
Copy Provided to	Dave Lyons; Bill Lee; Inspection Division Chief; inspector	