

Department of Public Utilities

Garrett County Sanitary District, Inc.

2008 Maryland Highway, Suite #2, Mtn. Lake Park, Maryland 21550

Telephone 301-334-6983 • Fax 301-334-6984 • E-mail: publicutilities@garrettcounty.org

TELEPHONE REPORT OF SEWAGE OVERFLOW

EMERGENCY PHONE # 866-633-4686

In What County did the Overflow Occur	Garrett	
Is this a combined sewer overflow (CSO)	YES <input type="radio"/> NO <input checked="" type="radio"/> (CIRCLE ONE)	
When did the Overflow Occur	DATE: 11/20/14	TIME 10:17 <input checked="" type="radio"/> AM <input type="radio"/> PM
Is the Overflow Ongoing or has it been repaired	ONGOING <input type="radio"/> REPAIRED <input checked="" type="radio"/> (CIRCLE ONE)	DURATION OF INCIDENT: 29 minutes
Location of the Overflow: Street, Manhole #, Pump Station name, etc.	1499 Deep Creek Drive 4" sump drain	
Cause of the Overflow - Get as much information as possible.	failed check valve at the main & failed anti-siphon in grinder basin allowed main line sewage to backup into house overflow toilet into sump pump which pumped outside	
What has been done to correct the Cause of the Overflow	check valve has been replaced and anti-siphon valve removed & capped	
Did any of the Overflow Waste Water enter Waters of the State (includes storm drains)	YES <input checked="" type="radio"/> NO <input type="radio"/> (CIRCLE ONE)	NAME OF THE BODY OF WATER (IF YES) Deep creek Lake
Has/will the public be notified? If yes. how?	Yes - area taped off & signs posted; website; local paper (weekly) next week; radio announcement;	
Has/will the affected water body be posted as being contaminated?	Yes - signs posted on shoreline	
Estimated Quantity of the Overflow in GALLONS	1,740 gallons	
What type of Clean-up or other mitigation is being performed or scheduled to be performed	cleaned up with vacuum truck; debris and leaves touched by spill raked up; lime stabilized; ecoli sampling performed & continuing	
Name of the Person Reporting the Overflow	NAME: John Miller TITLE: Superintendent	PHONE: 301-501-1109
Name and type of Facility	FACILITY NAME: Deep Creek Lake WWTP	TYPE OF FACILITY: collection
Written Follow-up Notice	REMINDE THE CALLER THAT A WRITTEN FOLLOW-UP IS REQUIRED WITHIN 5 CALENDER DAYS (UNLESS THIS IS A CITIZEN COMPLAINT)	
Name of Staff Receiving Report	Mahogany @ MDE	
Date and Time of Report	DATE: 11/21/14	TIME: 10:15 <input checked="" type="radio"/> AM <input type="radio"/> PM
Name of Staff Report was referred to for follow-up		
Copy Provided to	Dave Lyons; Bill Lee; Inspection Division Chief; inspector	

on 11/20/14 @ 11:54 am Tina Buckel @ GCHD notified & Eric Knowle from DNR - both on scene @ 1:00 pm